


Superconducting Linac Operations and Performance

SNS AAC Review

January 10, 2012

SANG-HO KIM

Superconducting Linac Systems Group



Outline

- **SCL operational status at last review**
- **Action items**
- **SCL operational status since last review**
- **SCL performances & issues**
- **Plans for 1.4 MW**
- **Summary**

SNS SRF Cavity



Main Specifications:

$E_a = 15.9$ MV/m at $\beta = 0.81$

$E_a = 10.2$ MV/m at $\beta = 0.61$


&

$Q_o > 5E9$ at 2.1 K



SNS Cryomodule

Designed to operate at 2.1 K (superfluid helium)






SCL status at last review

- **Supports Neutron production at 928 MeV up to 1 MW with >98 % availability (including SCL related systems)**
- **Improvements**
 - One additional HVCM; Available RF power enough for 26 mA design average beam current
 - 9 Thales klystrons were replaced with CPI klystrons due to output instability
 - DC biasing for selected cavities; MP induced coupler heating
 - Coupler water temperature alarm; water condensation
 - Temporary fix for LLRF IOC; AFF learning issue, IOC overloading issue
- **Issues**
 - 1 incident from water condensation at air side of coupler
 - 2 incidents from errant beam → performance degradation
 - LLRF IOC overloads
- **SRF activities (in-situ processing, spares CMs: tomorrow's talk)**

Errant beam in SCL



- **MPS**
 - When any RF HPM PV counts and/or
 - When BLM signal touches the threshold
 - MPS signal → RFQ/LEBT chopper shut off
 - MPS delay is supposed to be 20-30 us
- Had performance degradations with 2 cavities (5a, 6c) → claimed that errant beam is too frequent and MPS delay looks long
- Measured all MPS delay in the linac; 50-300 us



Errant beam from the source
Now MPS delay <30 us

Performance degradation of SRF cavities by errant beam

- First time in 4-years operation + commissioning in Nov. 2009
- Limiting gradient of two cavities (5a, 6c); 14.5 MV/m due to FE → Partial quench at 9 MV/m and became worse → turned off
- Errant beam between MPS trigger and beam truncation → off-energy beam with AFF → much bigger beam loss downstream → gas burst → redistribution of gas/particulate → changes in performance/condition
- Random, statistical events; resulted in surface contamination → worse end group stability



Action Items (I)

- For the immediate term: Continue RF processing of cavities 5a and 6c to try to recover the original performance. The result will be decisive for further actions. (AAC2010)

→ 5a: conditioned up to 11 MV/m (operation gradient was 10.5 MV/m before errant beam incident)

6c: thermally cycled up to room temperature and conditioned up to 10 MV/m (operation gradient was 13 MV/m before errant beam incident). Not fully recovered. Still see electron activities at the end group.

- It is recommended to carefully examine the hardware and software of the MPS to provide fail safe operation, even under extraordinary operating conditions. (AAC2010)

→ Done by the Controls Systems Group. MPS delay is now about 30 us or less.

Action Items (II)

- Finalize and implement “in situ” plasma cleaning technology (AAC2010)

→ Pending

- For the near term: Assemble and exchange the spare module (after replacing a poor performing cavity so that module meets the PUP spec) (AAC2010)

→ Plan on taking CM20 out from the tunnel in summer down (or next winter down depending on spare cryomodule test results and other operational conditions).

Action Items (III)

- **The committee acknowledges the professional and successful activity of the SRF group at SNS. In order to assure a long lasting implementation of this effort, the committee recommends the re-examination of the presently highly matrixed organization, and consideration of the formation of a specific group within RAD. (AAC2009)**

→ SRF group was formed within RAD in Nov. 2010


- 4 members + 1.5 matrixed + 3 FTE supported from RF, Control, Mechanical

→ SCL systems group in Nov. 2011

- Cryogenic systems group and SRF group combined
- 12.5 members + 4 FTE supported from RF, Control, Mechanical
- SCL, CHL, SRF/Cryo Facilities, R&Ds, support for other groups/organizations


SCL operational status since last review (I)

- 925 MeV + (0-12 MeV energy reserve) with high availability
- Down time statistics of SCL and related systems in FY11
- Total down time: 90.7 hours (98.2 %)
- 70 % of cavity trips by errant beam



Down time statistics of SCL and related systems in last run (Aug.-Dec.11)

- About 98.4 % availability
- 70 % of cavity trips from errant beam



High availability

- **Operational flexibility of SCL: energy reserve is essential**
- **Proactive maintenance**
- **Down times till full recovery, if**
 - **Cryomodule warm-up is needed: 8-10 days**
 - **2K Cold box trips: 10 hours**
 - **More coupler flow is needed: 5 hours**
 - **Small part/board changes in the klystron gallery: 3 hours**
 - **SCL is retuned: 3 hours (using energy reserve)**
 - **To circumvent problems that can't be addressed during operation or to minimize a down time**
 - **Every run (~5 month) needed 2-3 times retuning**

SCL operational status since last review (II)

- **Tuner repairs**
 - **5c (Feb. 2010): tuner malfunction found at machine start-up**
 - **Since then, implement tuner test procedure at every shut-down and start-up**
 - **17b, 23b: showed irregular vibration (Jul. 2010): motor and/or HD**
 - **9b: has shown irregular vibration and is not functioning after 4 K transition on 12/23/2011 → repair is ongoing**
- **Coupler air side water condensation:**
 - **Low temperature alarm has been implemented**
 - **All have dry air purging system**
- **New LLRF IOC: resolved IOC overload problem**

SCL operational status since last review (III)


- **CHL trips (5 times since last review)**
 - **CC2 speed sensor, CC3 displacement sensor: inspection on going**
 - **Heater PS failure: Safeguard to PLC logic during this down time**
 - **Ground fault, Power distribution switchgear loose wiring**
- **CHL turbine 1 (T1) failure in Dec. 2010: replaced in Jan. 2011**
 - **Inspected T2 & T4 last week**
 - **Found possible explanation for T1 failure. Further monitoring is ongoing**

SCL operational status since last review (IV)

- **5a, 6c conditioning: partial recovery**
 - RF conditioning:
 - 5a conditioned up to 11 MV/m (10.5 MV/m before errant beam hits)
 - 6c conditioned up to <10 MV/m (13 MV/m before errant beam hits)
 - CM6 warm-up
 - 6c conditioned up to 12 MV/m (still see instability at the end group)
- **20d: higher beam line vacuum $\sim 1.5e-8$ torr (possible air leak caused by errant beam events)**
 - No degradation of cavity gradient observed
 - Turned off in Oct. 11 as a precautionary measure
- **12b: end group partial quench at lower gradient after recovery from 2KCB trip in Nov. 11**
- **19b: dynamic cryo-load has increased by factor of 8 during last run**
- **Ion pump failure: Warm section between CM18 & 19 (Oct. 11)**
 - No vacuum reading when IP fails (vulnerability: need spare vacuum reading)


Operating gradients

- 5a, 6c: partially recovered
- 12b: end group partial quench at lower gradient after recovery from 2KCB trip in Nov. 11
- 20d: higher beam line vacuum $\sim 1.5e-8$ torr (possible air leak caused by errant beam events)



Errant beam events around CM20

- BLM trips: Several times/day
- Cavity 20d: ~ 0.4 cavity trips/day
- 20d RF recovery was OK but trips were getting more frequent and vacuum has been staying at 1.5×10^{-8} torr (same reading for both CCGs)



FMEA for CHL (M. Howell et. al.)

- **Failure Modes and Effects Analysis**
 - Break the work down to task level for analysis
 - This process delivers
 - Weaknesses in our process
 - Ranked items in need of focus
 - An opportunity for a group to focus on a process
- **Process Failure Modes and Effects Analysis (PFMEA) for CHL process**
 - Evaluates process functions
 - Identifies failure modes and their effect
 - Lists potential causes
 - Specifies process variables for process control
 - Enables a prioritization system (RPN)
 - Documents corrective action activities
- **Started in FY09: ~ 300 items are identified. Proactive maintenances are go going. Lots of improvements since then.**

FMEA example

- **What happens if a JT actuator fails?**
 - Loss of control of liquid level in cryomodule
 - Requires depressurization of supply transfer line to replace
 - Shut down neutron production and 2KCB
 - Regularly occurring problem with high severity
- **Developed tooling and procedure to allow for an actuator change without depressurizing**
 - Practiced change on Dummy Cryomodule at pressure
 - Lowers severity from 7 to 4
 - Lowers RPN from 196 to 112
- **Working on detection method to lower it to 64**

For Design Beam Power 1.44 MW


- Present gradient settings are based on collective limits at 60 Hz
 - Main limiting factor is field emission
 - Thermal instability at the end group
 - Presently beam energy (925 MeV) is lower than design (1000 MeV)
 - There are large scattering in cavity performances
- Strategy for long term sustainability and for reaching 1 GeV+25 MeV energy reserve
 - **SRF facility:** For offline rework capability, cryomodule development and R&D
 - **Spare cryomodule:** To replace low performing/damaged cryomodule
 - **Plasma processing:** To recover from cavity gradient degradation and to Increase High beta cavity gradients by 15%

Collective behaviors



individual limits; 19.5, 15, 17, 14.5 MV/m
collective limits; 14.5, 15, 15, 10.5 MV/m

Example: CM13

b cavity phase → a cavity beam pipe





a cavity phase → a cavity beam pipe



Collective behaviors

- Example: CM19
- Radiation signal at the upstream of CM19



Motivation for in-situ processing in the tunnel

- **Medium term**
 - Recover from cavity performance degradations
 - Reach 1GeV + energy reserve (Increase high beta cavity gradients by about 2 MV/m on average)
- **Long term**
 - 42-mA beam loading with 2nd target station: Need narrower performance scattering → Efficient utilization of RF power (ideally constant RF power/cavity is preferred)
- Develop a **cost effective** processing method with minimal impact on machine operation

Cryomodule Rework


- **Only option for unrecoverable damages**
- **High beta spare is about complete**
 - Rework cryomodule 20
 - Possible air leak across RF window on cavity 20d
 - Cavity 20d currently turned off
 - Rework cryomodule 13
 - Superfluid leak, possible HOM feedthrough leak
 - Large variation between individual and collective limits
- **Medium beta spare is in planning**
 - Rework cryomodule 9
 - Large air leak to insulating vacuum: has separate pumping cart in the tunnel
 - Rework cryomodule 11
 - Cavity 11b has never worked, HOM problem
 - May require full disassembly
- **Performance degradations have been observed in some cavities. Need proactive preparation for spares cryomodule and plans for rework.**

PUP-SCL portion for STS


- 8+1 cryomodules for 42 mA, 1.3 GeV + energy margin
- Strategy for RF power, Coupler average power, Eacc

* RF power, 15 % RF control margin included in plots

Present Eacc+13.7 MV/m for PUP cavity
Eacc and *RF power required at klystrons



PUP design parameters in 2006
Eacc and *RF power required at klystrons




PUP-SCL portion for STS

- 8+1 cryomodules for 42 mA, 1.3 GeV + energy margin
- Strategy for RF power, Coupler average power, Eacc
- About constant power/cavity is preferable for existing ones
- Need processing or rework for lower performers


Eacc for STS

Eacc and *RF power required at klystrons



Eacc comparisons

Eacc and *RF power required at klystrons



PUP SCL Portion: Basis of Design

- **Cavity performance requirements**
 - Stable operating gradient: 13.7 MV/m average
 - Field emission onset: >12 MV/m
- **Pressure boundary is compliant with 10 CFR 851**
 - Conducted internal and external reviews
 - Vacuum vessel built to ASME BPVC Section VIII
 - Helium piping built to ASME B31.3
 - All welding conducted in accordance with ASME code
- **Interface points are the same as previous design**
 - U-tube connections held constant
 - Waveguide connections held constant
 - Instrumentation connections are very similar with the exception of the Joule-Thomson valves
- **SCL Design Criteria Document complete (PUP0-302-DC0001)**

Summary

- **Support Neutron Production at 925 MeV up to 1 MW**
 - High reliability: operational flexibility and proactive maintenance
 - Energy margin: essential
 - RF capability/Eacc settings: enough for design beam current 26 mA
- **Next run preparation**
 - Will try to recover cavity performances: may have to run at lower beam energy to maintain some energy reserve
 - Equipment/part maintenances
- **Plans for long term sustainability and reaching design beam power 1.44 MW**
 - SRF facilities
 - Spare cryomodules for rework
 - In-situ plasma processing